



General Water Analysis
Distribution System
2022

<u>Analyte</u>	<u>Results</u>	<u>MCL</u> <u>(Maximum Contaminant Level)</u>
Lead	< 10.0 ug/L	15.0
Copper	1.4 ug/L	1300
Nitrate as N	< 0.10 mg/L	10.0
Chloride	12.9 mg/L	NA
Iron	<50.0 ug/L or 0.0500 mg/L	NA
Manganese	2.2 ug/L or 0.0022 mg/L	NA
pH	7.6 Std. units	NA
Solids, Total Dissolved	390 mg/L	NA
Turbidity	<0.50 NTU	NA
Alkalinity, Total	320 mg/L	NA
Solids, Total Suspended	<10 mg/L	NA
Calcium	94000 ug/L or 94.0 mg/L	NA
Magnesium	29200 ug/L or 29.2 mg/L	NA
Zinc	<5.0 ug/L or .005 mg/L	NA
Hardness	346 mg/L or 20.8 grains per gallon	NA